


FRONT VIEW

SIDE VIEW

- NOTES:
1. ENCLOSURE FOR HEATER WIRING ONLY.
  2. AS SHOWN FOR USE WITH UP TO EIGHT RT/RTF FLEXIPANELS. INSTALL AS PER INSTRUCTIONS SUPPLIED WITH HEATER.
  3. ENCLOSURE IS NEMA 4X RATED HOFFMAN TYPE A-12106CHSCFCG.
  4. AS SHOWN FOR 240 V APPLICATION.



WIRING

EXAMPLE - EIGHT HEATERS

REV	DATE	DESCRIPTION OF REVISION	DRAWN	DESIGNED	REVIEWED	APPROVED
1	1/9/02	ADDED T&B 5262	RJT	RJT	HH	AM
0	11/13/00	INITIAL ISSUE	RJT	RJT	HH	AM

JB-8-SO 5 TO 8 HEATERS 240 V PART # 26105		THERMON MANUFACTURING COMPANY THE HEAT TRACING SPECIALISTS®		THERMON PROJECT NUMBER THERMON DWG. NO. H-26105-28	
ISO 9001 CERTIFIED COMPANY		THIS DRAWING IS THE PROPERTY OF THERMON. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE WRITTEN PERMISSION OF THERMON. SUBJECT TO RETURN ON DEMAND. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.		DISK# H-26105.2	
SHT. 1/1		REV. 1			