



NOTES:

1. ENCLOSURE FOR HEATER WIRING ONLY.
2. AS SHOWN FOR USE WITH FOUR RT/RTF FLEXIPANELS.
3. ENCLOSURE IS NEMA 4X RATED HOFFMAN TYPE A-12106CHSCFG.
4. AS SHOWN FOR 120 V APPLICATION.

REV	DATE	DESCRIPTION OF REVISION	DRAWN	DESIGNED	REVIEWED	APPROVED
1	11/5/01	ADDED T&B 5262	RJT	RJT	HH	AM
0	2/23/00	INITIAL ISSUE	RJT	RJT	HH	AM

JB-4-RT
120 VOLT, 4 HEATERS
PART # 26118

THIS DRAWING IS THE PROPERTY OF THERMON MANUFACTURING COMPANY. IS CONFIDENTIAL AND MUST NOT BE MADE PUBLIC OR COPIED AND IS SUBJECT TO RETURN ON DEMAND. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
ISO 9001 CERTIFIED COMPANY

THERMON PROJECT NUMBER
THERMON MANUFACTURING COMPANY
THE HEAT TRACING SPECIALISTS

THERMON DWG. NO.
H-26118-14

SHT. 1/1 **REV. 1**

DISK# H-26118.1